



- Ⓐ MINIMUM 1" CTS 200 PSI POLY SERVICE LINE
 - Ⓑ 1" INSERT STIFFENER
 - Ⓒ 1" CTS X 3/4" MIP COMPRESSION FITTING
 - Ⓓ 3/4" I.P. BRONZE GATE VALVE OR BALL VALVE
 - Ⓔ 3/4" X 2" BRASS PIPE NIPPLE
 - Ⓕ 3/4" I.P. BRONZE DUAL CHECK VALVE
 - Ⓖ 3/4" BRASS PRESSURE REDUCING VALVE
 - Ⓗ 3/4" X 4" BRASS PIPE NIPPLE
 - Ⓙ 3/4" BRASS TEE FITTING
 - Ⓚ 3/4" WROT COPPER X M.I.P. FITTING
 - Ⓛ PRESSURE/SHOCK ABSORBING AIR CELL
 - Ⓜ 3/4" BACKFLOW PREVENTER REQUIRED FOR COMMERCIAL, INDUSTRIAL, AND AGRICULTURAL SERVICES AND ALL SERVICES WITH A AUXILIARY WATER SUPPLY.
- * IF CUSTOMER HAS THE SERVICE LINE RAN, THE 3/4" F.I.P. X SIZE OF PIPE FITTING TAPED TO PIPE SERVICE WILL BE CONNECTED AT TIME SERVICE IS INSTALLED.

NORTHERN OHIO RURAL WATER

RECOMMENDED RURAL WATER
CONNECTION 3/4" SERVICE
SCALE: NTS

